

Rolling Door Industries LLC
8214 NW 64 Street
Miami, Florida
USA 33166

Listing Number: F470-1
Project Number: F470-1 Edition 1

Attention: Mr. Ernesto Rodriguez, President

**Subject: LISTING OF FIRE AND SMOKE RATED DOORS TO THE FOLLOWING STANDARDS
PER QAI'S GENERAL CERTIFICATION SCHEME:**

- **UL 10B (2016)** *Standard for Fire Tests of Door Assemblies*
- **CAN/ULC-S104 (2015)** *Standard Method for Fire Tests of Door Assemblies*
- **UL 1784 (2020)** *Standard for Air Leakage Tests of Door Assemblies and Other Opening Protectives*

Dear Sir,

We are pleased to confirm effective the date noted below, we have listed the subject product in the QAI Directory of Listed Products available for viewing at: <http://qai.org/listing-directory/> Descriptions of Listed Products can be found on page 2 of this letter.

Please review the attached listing and web listing to make sure it is accurate and feel free to add the above link to your product website as confirmation to consumers and regulators of QAI Listing. If you note any errors in the attached listing, please advise your project manager immediately.

The subject product is eligible to bear the QAI logo shown below in accordance with the QAI Listing Agreement dated September 30, 2020.



QAI is accredited by the Standards Council of Canada (SCC) and International Accreditation Service (IAS) as a third party product certification body.

Proposed usage of the QAI mark must be submitted to your QAI project manager for review prior to publish. Products for end use in Canada are required to have markings in both French and English. It is the responsibility of the Applicant to apply bilingual markings as required by the applicable evaluation listing reports and in accordance with State, Provincial and Territorial Regulatory Authorities.

Yours truly,
QAI LABORATORIES

Kent Adamson, President

December 8, 2020

Date

Encl: Copy of entry in the QAI Listing Directory

Current listings may be verified by visiting the Directory of Listed Products at www.qai.org

LISTED PRODUCTS:

Spec. Owner	Maximum Dimensions		Door Type	QAI Report #	Fire Rating:
	Width *	Height *			
Rolling Door Industries LLC	10'0" (3048 mm)	10'0" (3048 mm)	Interlocking 3.1" Metal Slats with 2.6" exposure Fire Rated only	F470-1-180-MFG	180 Min Neutral Pressure
Rolling Door Industries LLC	10'0" (3048 mm)	10'0" (3048 mm)	Interlocking 3.1" Metal Slats with 2.6" exposure Fire and Smoke Rated	F470-1-180-MFG	180 Min Neutral Pressure

* Note: The 10' x 10' door size was tested at the maximum dimensions of the door allowed by the QAI test furnace. The door types listed above are permitted to be constructed oversized, with the maximum permitted dimensions 30' x 30' (9144 mm x 9144 mm). Additional label is required on the oversized doors, see the "Markings" section of the QAI Evaluation Report # F470-1.

Permitted Slat Options	
Material:	<ul style="list-style-type: none"> Galvanized steel Stainless steel
Metal gauge:	<ul style="list-style-type: none"> 22 gauge 20 gauge 18 gauge
Finish:	<ul style="list-style-type: none"> Bake on enamel paint Powder coat paint Unpainted galvanized or stainless steel
Insulation:	<ul style="list-style-type: none"> No insulation – no back slat required 16 mm (5/8 in.) thickness mineral wool with 24 gauge back slat

Current listings may be verified by visiting the Directory of Listed Products at www.qai.org